

TRANSMITTAL OF SUBMITTAL

DATE: 3/3/23

TO: Scott Miller

CMG - City of Atlanta
2528 Chattahoochee Circle
Atlanta, GA 30318

New X-Submittal Resubmittal

Project: East Area Water Quality Control Facility
Improvements

Specification Section No. : 16361

Supplier/Vendor/Subcontractor: Contessa

FROM: LAKESHORE ENGINEERING

1259 Ellsworth Drive

Atlanta, GA 30318


Manufacturer: EATON

The following items are hereby submitted:

Number of Copies	Description of Item Submitted (Type, Size, Model Number, Etc.)	Submittal number	Submittal Type	Contains Variation to Contract	
				No	Yes
Email	Misc. Breakers	16361-58.00	Product Data	X	

Comments/Variation:

CONTRACTOR hereby certifies that (i) CONTRACTOR has complied with the requirements of Contract Documents in preparation, review, and submission of designated Submittal and (ii) the Submittal is complete and in accordance with the Contract Documents and requirements of laws and regulations and governing agencies.

By: _____

 Brandon Dow

Project Name: East Area Water Control Facility
General Order No: MAT0011132

Negotiation No: AT130311X0K1
Alternate No: R003

Item No.	Qty	Product	Description
036	6	HEAVY DUTY SAFETY SW	30A/3P HD NON-FUSIBLE SAFETY SWITCH 600V NEMA 4X S
		Catalog No	DH361UWK
	Qty	List of Materials	
	6	30A/3P HD NON-FUSIBLE SAFETY SWITCH 600V NEMA 4X S	
Item No.	Qty	Product	Description
037	8	HEAVY DUTY SAFETY SW	60A/3P HD Non-Fusible Safety Switch 600V Nema 4X S
		Catalog No	DH362UWK
	Qty	List of Materials	
	8	60A/3P HD Non-Fusible Safety Switch 600V Nema 4X S	
Item No.	Qty	Product	Description
038	1	Safety Switches	Safety Switches
		Catalog No	DH362UWK
		Designation	60A 4X
	Qty	List of Materials	
	1	Heavy Duty Switch - Non-Fusible, 3-Pole, 600 VAC, 60 A, NEMA 4X (304 Stainless)	
Item No.	Qty	Product	Description
039	7	MCCB SERIES C	TYPE GHB BREAKER 3P 20A 277/480VAC MAX 125/250VDC
		Catalog No	GHB3020
		Designation	HSP
	Qty	List of Materials	
	7	TYPE GHB BREAKER 3P 20A 277/480VAC MAX 125/250VDC	
Item No.	Qty	Product	Description
040	1	MCCB SERIES C	TYPE GHB BREAKER 2P 20A 277/480VAC MAX 125/250VDC
		Catalog No	GHB2020
		Designation	HSP
	Qty	List of Materials	
	1	TYPE GHB BREAKER 2P 20A 277/480VAC MAX 125/250VDC	

Item No.	Qty	Product	Description
041	1	MCCB SERIES C	TYPE GHB BREAKER 3P 40A 277/480VAC MAX 125/250VDC
		Catalog No	GHB3040
		Designation	HSP

Project Name: East Area Water Control Facility
General Order No: MAT0011132

Negotiation No: AT130311X0K1
Alternate No: R003

Qty **List of Materials**
1 TYPE GHB BREAKER 3P 40A 277/480VAC MAX 125/250VDC

Item No.	Qty	Product	Description
042	1	PANEL BUILDERS	TYPE BAB CIRCUIT BREAKER 1P,20AMP, 120/240V,10,000

Catalog No BAB1020

Qty **List of Materials**
1 TYPE BAB CIRCUIT BREAKER 1P,20AMP, 120/240V,10,000

Item No.	Qty	Product	Description
043	1	PANEL BUILDERS	BAB3020H BRKR A

Catalog No BAB3020H

Qty **List of Materials**
1 BAB3020H BRKR A

Item No.	Qty	Product	Description
044	9	PANEL BUILDERS	QBHW breaker 1 pole 20 amp

Catalog No QBHW1020
Designation LSP

Qty **List of Materials**
9 QBHW breaker 1 pole 20 amp

Item No.	Qty	Product	Description
045	2	PANEL BUILDERS	2 Pole 20 Amp QBHW Breaker

Catalog No QBHW2020
Designation LSP

Qty **List of Materials**
2 2 Pole 20 Amp QBHW Breaker

Item No.	Qty	Product	Description
046	1	PANEL BUILDERS	3 Pole 40 Amp QBHW Breaker

Catalog No QBHW3040H
Designation LVPC

Qty **List of Materials**
1 3 Pole 40 Amp QBHW Breaker

Eaton Selling Policy 25-000 applies.

All orders must be released for manufacture within 90 days of date of order entry. If approval drawings are required, drawings must be returned approved for release within 60 days of mailing. If drawings are not returned accordingly, and/or if shipment is delayed for any reason, the price of the order will increase by 1.0% per month or fraction thereof for the time the shipment is delayed.

EATON

Powering Business Worldwide

EATON

Powering Business Worldwide



Powering Business Worldwide

Project Name: East Area Water Control Facility
General Order No: MAT0011132

Negotiation No: AT130311X0K1
Alternate No: R003

Item No.	Qty	Product	Description
042	1	PANEL BUILDERS	TYPE BAB CIRCUIT BREAKER 1P,20AMP, 120/240V,10,000

Catalog No BAB1020

Qty List of Materials

1 TYPE BAB CIRCUIT BREAKER 1P,20AMP, 120/240V,10,000

Item No.	Qty	Product	Description
043	1	PANEL BUILDERS	BAB3020H BRKR A

Catalog No BAB3020H

Qty List of Materials

1 BAB3020H BRKR A

Item No.	Qty	Product	Description
044	9	PANEL BUILDERS	QBHW breaker 1 pole 20 amp

Catalog No QBHW1020
Designation LSP

Qty List of Materials

9 QBHW breaker 1 pole 20 amp

Item No.	Qty	Product	Description
045	2	PANEL BUILDERS	2 Pole 20 Amp QBHW Breaker

Catalog No QBHW2020
Designation LSP

Qty List of Materials

2 2 Pole 20 Amp QBHW Breaker

Item No.	Qty	Product	Description
046	1	PANEL BUILDERS	3 Pole 40 Amp QBHW Breaker

Catalog No QBHW3040H
Designation LVPC

Qty List of Materials

1 3 Pole 40 Amp QBHW Breaker

Eaton Selling Policy 25-000 applies.

All orders must be released for manufacture within 90 days of date of order entry. If approval drawings are required, drawings must be returned approved for release within 60 days of mailing. If drawings are not returned accordingly, and/or if shipment is delayed for any reason, the price of the order will increase by 1.0% per month or fraction thereof for the time the shipment is delayed.

Seller shall not be responsible for any failure to perform, or delay in performance of, its obligations resulting from the COVID-19 pandemic or any future epidemic, and Buyer shall not be entitled to any damages resulting thereof.

EATON

Powering Business Worldwide

EATON

Powering Business Worldwide

EATON

Powering Business Worldwide



Detail Bill of Material

Project Name: East Area Water Control Facility
General Order No: MAT0011132

Negotiation No: AT130311X0K1
Alternate No: R003

Item No.	Qty	Product	Description
039	7	MCCB SERIES C	TYPE GHB BREAKER 3P 20A 277/480VAC MAX 125/250VDC
		Catalog No	GHB3020
		Designation	HSP
	Qty	List of Materials	
	7		TYPE GHB BREAKER 3P 20A 277/480VAC MAX 125/250VDC

Item No.	Qty	Product	Description
040	1	MCCB SERIES C	TYPE GHB BREAKER 2P 20A 277/480VAC MAX 125/250VDC
		Catalog No	GHB2020
		Designation	HSP
	Qty	List of Materials	
	1		TYPE GHB BREAKER 2P 20A 277/480VAC MAX 125/250VDC

Item No.	Qty	Product	Description
041	1	MCCB SERIES C	TYPE GHB BREAKER 3P 40A 277/480VAC MAX 125/250VDC
		Catalog No	GHB3040
		Designation	HSP
	Qty	List of Materials	
	1		TYPE GHB BREAKER 3P 40A 277/480VAC MAX 125/250VDC

Eaton Selling Policy 25-000 applies.

All orders must be released for manufacture within 90 days of date of order entry. If approval drawings are required, drawings must be returned approved for release within 60 days of mailing. If drawings are not returned accordingly, and/or if shipment is delayed for any reason, the price of the order will increase by 1.0% per month or fraction thereof for the time the shipment is delayed.

Seller shall not be responsible for any failure to perform, or delay in performance of, its obligations resulting from the COVID-19 pandemic or any future epidemic, and Buyer shall not be entitled to any damages resulting thereof.